

Chris Nash

From: [REDACTED]
Sent: 24 June 2019 11:24
To: Chris Nash
Subject: RE: Invalid Application - Further Details Required - App ref 9/2019/0565

Dear Chris

The odour impact assessment I included in our application documentation is a generic report. The testing took place at our stores in Reading and in Bracknell, as being typical examples of Greggs' shop locations, with Reading having sensitive residential accommodation above the shop and Bracknell having no sensitive residential accommodation within 50 m of the property. We use the same basic extract equipment and system in all our stores; what determines whether additional filters and noise suppressing measures are installed is whether there is sensitive residential accommodation within 20 m of the extraction point. I trust this clarifies the issue, but should you have any further queries, please do not hesitate to contact me.

Regards
Sara Humphries
Greggs plc
Tel: [REDACTED]