

Jessica Cheadle

From: Neil Thompson
Sent: 03 August 2021 12:42
To: SDDC Planning Applications
Subject: FW: DMPA/2021/0417 - Dog Agility Building at Church Broughton

I've taken off some of the previous correspondence to clean it up.

Kind regards

Neil Thompson
Planning Officer – Service Delivery
T: 07920446816
www.southderbyshire.gov.uk



From: John Mills <John.Mills@southderbyshire.gov.uk>
Sent: 03 August 2021 10:26
To: Neil Thompson <Neil.Thompson@southderbyshire.gov.uk>
Subject: RE: DMPA/2021/0417 - Dog Agility Building at Church Broughton

Neil,

I've had a look through the appended noise information, and I have no confidence in the noise report submitted by the applicant. For example, the report quotes a noise reduction of a 2 metre high brick wall as being the same as the manufacturers sound reduction index. This is fine if the material in question forms a complete enclosure, but with a wall the noise simply goes over the top. As a result a 2 metre wall will give, at best, a reduction of 10-15 dB(A) not the 40 dB(A) being quoted here.

My recommendation is that the application is refused as the applicant has not demonstrated noise will be contained to my satisfaction.

Kind regards,

John Mills
Principal Environmental Health Officer
Environmental Protection
T: 01283 595903
www.southderbyshire.gov.uk





Our Environment | Our People | Our Future

www.southderbyshire.gov.uk



South
Derbyshire
District Council