
From: John Mills
Sent: 12 May 2022 09:32
To: SDDC Planning Applications
Subject: RE: Application ref. DMPA/2022/0494: Consultation on planning application

I can confirm that I have no objection to the proposals in principle, however I recommend the following conditions:

1. a) No development shall commence until a scheme to identify and control any contamination of land or pollution of controlled waters has been submitted to and approved in writing by the Local Planning Authority, and until the measures approved in that scheme have been implemented. The scheme shall include all of the measures (phases II to III) detailed in Box 1 of Section 3.1 of the Council's 'Guidance on submitting planning applications for land that may be contaminated' (herein referred to as 'the Guidance'), unless the Local Planning Authority dispenses with any such requirement specifically and in writing.
b) Prior to occupation of the development (or parts thereof) an independent verification report which meets the requirements given in Box 2 of Section 3.1 of the Guidance shall be submitted to and approved in writing by the Local Planning Authority. With the prior written agreement of the Local Planning Authority pursuant to part (a) of this condition, this may be carried out on a plot-by-plot basis.
c) In the event that it is proposed to import soil onto site in connection with the development, this shall comply with the specifications given in Box 3 of Section 3.1 of the Guidance.
d) If required by the conceptual site model, no development shall commence until monitoring at the site for the presence of ground gas and a subsequent risk assessment which meets the requirements given in Box 4, Section 3.1 of the Guidance has been completed in accordance with a scheme first submitted to and approved in writing by the Local Planning Authority.


2. Recharge points for electric vehicles shall be provided within the development to comply with the following criteria:

- Residential – At least 1 charging point per dwelling with dedicated on plot parking, or 1 charging point per 10 spaces (or part thereof) where the dwelling(s) are served by courtyard or roadside parking;

Residential charging points shall be provided with an IP65 rated domestic socket 13amp socket, directly wired to the consumer unit with 32 amp cable to an appropriate RCD. This socket shall be located where it can later be changed to a 32amp EVCP. Non-residential charging points shall be supplied by an independent 32 amp radial circuit and equipped with a type 2, mode 3, 7-pin socket conforming to IEC62196-2. Alternative provision to this specification must be first submitted to and approved in writing by the Local Planning Authority. To prepare for increased demand in future years suitable and appropriate cable provision shall be included in the scheme design in accordance with details first submitted to and approved in writing by the Local Planning Authority. The electric vehicle charging points shall be provided in accordance with the stated criteria and approved details prior to the first occupation or use of the respective premises and shall thereafter be maintained in working order and remain available for use throughout the life of the development.

Kind regards,

John Mills
South Derbyshire District Council
Principal Environmental Health Officer
Environmental Protection
T: 01283 595903
M: 07976 081884
www.southderbyshire.gov.uk



From: Planning Applications <planningapplications@southderbyshire.gov.uk>
Sent: 11 May 2022 13:14
To: Environmental Health <Environmental.Health@southderbyshire.gov.uk>
Subject: Application ref. DMPA/2022/0494: Consultation on planning application

Conversion of the existing agricultural barn to create a three bedroomed dwelling, and associated ancillary space at Agricultural Buildings, Burntheath Lane, Hilton, Derby DE65 5FE

The above planning application has been received. The details can be viewed online at <https://planning.southderbyshire.gov.uk/dmapps.aspx?ref=DMPA/2022/0494>.

Timeframe for, and how and where to send a response

Due to the need to issue a decision within a statutory timeframe, I must receive your full comments promptly and no later than **01/06/2022**. Failure to respond within this timeframe will be taken as indicative of your intention not to comment. We must also be able to circulate any pre-commencement conditions to the applicant no less than 10 days before a decision is due.

Please provide or attach your comments by return email, ensuring you quote the above application reference number.

Form and scope of response

I am seeking your comments in so far as it affects your interests. Please ensure any response clearly outlines (1) your current stance towards the proposal, (2) the reasons for your position, and (3) what conditions and/or obligations you would wish to see attached to any grant of permission. You are strongly recommended to use the enclosed pro-forma or set out your response in this manner.

Please note that conditions will only be attached where they fulfil [the tests for imposing conditions](#) as set out in Planning Practice Guidance and conditions which require the submission and approval of information before any works can commence ([pre-commencement conditions](#)) will only be imposed in exceptional circumstances. You should base your request on our list of model conditions.

If you object to the proposals as currently presented, please outline the full reasons for your objection as **there is no guarantee that amendments or further information will be sought or received**. If you consider amendments or further information could overcome your objection, please provide these as advisory notes.

When a decision is made the decision notice and officer report will be displayed online at the above link.

Yours faithfully

Steffan Saunders

Head of Planning and Strategic Housing

