

PRP

Page 1

Catherine House
Old Harborough Road
Brixworth NN6 9BX

Date 27/01/2022
File 81270 - SOAKAWAY BASIN ...

Micro Drainage

Shades Farm - 81270
1 in 1 year storm

Designed by AGS
Checked by DE

Source Control 2018.1.1

Micro Drainage

Summary of Results for 1 year Return Period

Half Drain Time : 214 minutes.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Control (l/s)	Max E Outflow (l/s)	Max Volume (m³)	Status
15 min Summer	110.344	0.044	1.3	0.0	1.3	11.7	O K
30 min Summer	110.356	0.056	1.4	0.0	1.4	15.1	O K
60 min Summer	110.371	0.071	1.5	0.0	1.5	19.2	O K
120 min Summer	110.388	0.088	1.5	0.0	1.5	23.7	O K
180 min Summer	110.399	0.099	1.5	0.0	1.5	26.5	O K
240 min Summer	110.406	0.106	1.5	0.0	1.5	28.5	O K
360 min Summer	110.415	0.115	1.5	0.0	1.5	31.0	O K
480 min Summer	110.420	0.120	1.5	0.0	1.5	32.3	O K
600 min Summer	110.422	0.122	1.5	0.0	1.5	33.0	O K
720 min Summer	110.424	0.124	1.5	0.0	1.5	33.5	O K
960 min Summer	110.426	0.126	1.5	0.0	1.5	34.0	O K
1440 min Summer	110.425	0.125	1.5	0.0	1.5	33.9	O K
2160 min Summer	110.421	0.121	1.5	0.0	1.5	32.5	O K
2880 min Summer	110.415	0.115	1.5	0.0	1.5	30.9	O K
4320 min Summer	110.402	0.102	1.5	0.0	1.5	27.6	O K
5760 min Summer	110.391	0.091	1.5	0.0	1.5	24.5	O K
7200 min Summer	110.381	0.081	1.5	0.0	1.5	21.9	O K
8640 min Summer	110.373	0.073	1.5	0.0	1.5	19.6	O K
10080 min Summer	110.366	0.066	1.5	0.0	1.5	17.7	O K
15 min Winter	110.348	0.048	1.4	0.0	1.4	13.0	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Discharge Volume (m³)	Time-Peak (mins)
15 min Summer	29.863	0.0	96.0	23
30 min Summer	19.436	0.0	99.3	37
60 min Summer	12.298	0.0	198.2	66
120 min Summer	7.625	0.0	202.6	126
180 min Summer	5.737	0.0	205.6	184
240 min Summer	4.683	0.0	207.8	244
360 min Summer	3.507	0.0	211.3	362
480 min Summer	2.842	0.0	213.8	480
600 min Summer	2.415	0.0	215.9	530
720 min Summer	2.113	0.0	217.7	594
960 min Summer	1.713	0.0	220.8	720
1440 min Summer	1.274	0.0	225.4	988
2160 min Summer	0.948	0.0	420.9	1408
2880 min Summer	0.769	0.0	425.1	1816
4320 min Summer	0.572	0.0	431.4	2600
5760 min Summer	0.464	0.0	731.6	3352
7200 min Summer	0.394	0.0	735.7	4104
8640 min Summer	0.345	0.0	739.3	4832
10080 min Summer	0.309	0.0	742.5	5456
15 min Winter	29.863	0.0	97.3	22

©1982-2018 Innovyze

PRP		Page 3
Catherine House Old Harborough Road Brixworth NN6 9BX	Shades Farm - 81270 1 in 1 year storm	
Date 27/01/2022 File 81270 - SOAKAWAY BASIN ...	Designed by AGS Checked by DE	
Micro Drainage		
Source Control 2018.1.1		

Rainfall Details

Rainfall Model	FSR	Winter Storms	Yes
Return Period (years)	1	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	19.300	Shortest Storm (mins)	15
Ratio R	0.400	Longest Storm (mins)	10080
Summer Storms	Yes	Climate Change %	+0

Time Area Diagram

Total Area (ha) 0.199

Time (mins)	Area	Time (mins)	Area
From: To:	(ha)	From: To:	(ha)
0 4	0.100	4 8	0.099

PRP		Page 4
Catherine House Old Harborough Road Brixworth NN6 9BX	Shades Farm - 81270 1 in 1 year storm	
Date 27/01/2022 File 81270 - SOAKAWAY BASIN ...	Designed by AGS Checked by DE	
Micro Drainage Source Control 2018.1.1		

Model Details

Storage is Online Cover Level (m) 111.000

Infiltration Basin Structure

Invert Level (m) 110.300 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.03816 Porosity 1.00
Infiltration Coefficient Side (m/hr) 0.03816

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	268.0	0.700	288.0

Pipe Outflow Control

Diameter (m) 0.150 Entry Loss Coefficient 0.500
Slope (1:X) 150.0 Coefficient of Contraction 0.600
Length (m) 4.000 Upstream Invert Level (m) 110.660
Roughness k (mm) 0.600

©1982-2018 Innovyze