

From: [Jo Crawshaw-Moore \(Place\)](#)
To: [Alex Matthews](#)
Cc: [SDDC Planning Applications](#)
Subject: RE: Application ref. DMPA/2024/0726: Consultation on planning application
Date: 24 September 2024 04:16:52 PM

CAUTION! This Email was sent from outside SDDC. Only open links and attachments you're expecting.

Good Afternoon Alex,

Thank you for consulting the Lead Local Flood Authority (LLFA) in relation to the above planning application. Apologies for the delay in our response.

A drawing 'Domestic Drainage Layout Sheet 1 of 2' (0102-01-P03) has been provided on which the drainage system is marked as 'National Highways Proposed'. Please clarify whether the drainage is part of the above planning application or not. If it is not, the LLFA would have no comment to make. If it is, the LLFA would require more information about the drainage:

- What total and impermeable areas are being drained?
- Is the discharge rate restricted and what is the rate?
- How will attenuation be provided?

The bund is in close proximity to a main river, therefore the Environment Agency should be consulted.

Kind regards,

Jo

**Jo Crawshaw-Moore | Senior Technician
Flood Risk Management**

Place | Derbyshire County Council

County Hall, Matlock, Derbyshire, DE4 3AG

T 01629 538584 M 07812 473016

E jo.crawshaw-moore@derbyshire.gov.uk

Visit us at www.derbyshire.gov.uk | Follow us on [Twitter](#) | Find us on [Facebook](#)